



PSB Singapore

# CERTIFICATE OF CONFORMITY

No. CLS2 16 03 92266 003

Initial No. CLS2 15 06 92266 001

**Certificate Holder:** **Vodapruf Pte Ltd**  
 8B Admiralty Street  
 #08-12  
 Singapore 757440  
 SINGAPORE

**Product:** Thermal Insulation Materials

**Brand Name:** LIGHTERM

**Model(s):** LIGHTERM

**Product Details:** Density: 150 kg/m<sup>3</sup>  
 (Classification: A2-s1, d0)  
 Analytical toxic fumes generated during  
 burning were below IDLH Value  
 (R is less than 0.3)

**Standard(s):** EN 13501-1:2007/A1:2009  
 BS 6853:1999 Annex B (NF X 70-100:2006)

**Country of Origin:** Malaysia

**Test Report(s):** See COC Appendix (1 pg)

**Issued on:** 2016-03-03

**Valid until:** 2018-06-08

Page 1 of 2

Vice-President (Certification Department)  
 TÜV SÜD PSB

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at [www.tuv-sud-psb.sg](http://www.tuv-sud-psb.sg)



PSB Singapore

# PRODUCT LISTING SCHEME APPENDIX

TO CERTIFICATE OF CONFORMITY NUMBER: CLS2 16 03 92266 003

Date of Issue : 2016-03-03

Issued To : **Vodapruf Pte Ltd**  
8B Admiralty Street  
#08-12  
Singapore 757440  
SINGAPORE

Test Report (s) : CSI No. 007\DC\REA\13\_1  
007\DC\REA\13\_2  
007\DC\REA\13\_3  
TÜV SÜD PSB No. 7191085872-CHM14-TSL

Vice President (Certification Department)  
TÜV SÜD PSB